

DIN EN 15316-2:2017-09 (E)

Energy performance of buildings - Method for calculation of system energy requirements and system efficiencies - Part 2: Space emission systems (heating and cooling), Module M3-5, M4-5

Contents

Page

European foreword	4
Introduction	5
1 Scope	7
2 Normative references	9
3 Terms and definitions	9
4 Symbols and abbreviations	10
4.1 Symbols	10
4.2 Subscripts	10
5 Description of the method	10
5.1 Output of the method	10
5.2 General description of the method	11
6 Calculation Method	11
6.1 Output data	11
6.2 Calculation time steps	12
6.3 Input data	12
6.4 Monthly and yearly calculation procedure	15
6.5 Hourly calculation procedure	20
7 Quality control	24
8 Compliance check	24
Annex A (normative) Template for choices, input data and references (Additional heating and cooling losses / auxiliary energy)	25
A.1 Introduction	25
A.2 Temperature variation for free heating surfaces (radiators), room heights 4 m (heating case)	26
A.3 Temperature Variation for component integrated heating surfaces (panel heaters) (room heights 4 m, heating case)	28
A.4 Temperature variation for air heating systems; room heights 4 m (heating case)	30
A.5 Temperature Variation for electrical heating (room heights 4 m, heating case)	31
A.6 Temperature Variation air heating (ventilation systems, room heights 4 m, heating case)	32
A.7 Temperature variation for room spaces with heights > 4 m (large indoor space buildings, heating case)	32
A.8 Temperature variation for room heaters fired by solid fuel	35
A.9 Temperature variation for water based cooling systems; room heights 4 m (cooling case)	36
A.10 Auxiliary Energy	37
A.11 Additional Information	38

Annex B (informative) Default choices, input data and references (additional heating and cooling losses / auxiliary energy)	40
B.1 Introduction	40
B.2 Temperature variation for free heating surfaces (radiators); room heights 4 m (heating case)	41
B.3 Temperature Variation for component integrated heating surfaces (panel heaters) (room heights 4 m, heating case)	43
B.4 Temperature variation for air heating systems; room heights 4 m (heating case)	45
B.5 Temperature Variation for electrical heating (room heights 4 m, heating case)	46
B.6 Temperature Variation air heating (ventilation systems, room heights 4 m, heating case)	47
B.7 Temperature variation for room spaces with heights > 4 m (large indoor space buildings, heating case)	47
B.8 Temperature variation for room heaters fired by solid fuel	50
B.9 Temperature variation for water based cooling systems; room heights 4 m (cooling case)	51
B.10 Auxiliary Energy	52
B.11 Additional Information	53
Bibliography	55